



Photo 1 – Non asbestos-containing domestic water pipe straight insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 2 – Asbestos-containing domestic water pipe joint insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Photo 3 – Asbestos-containing steam/condensate pipe straight insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Photo 4 – Asbestos-containing steam/condensate pipe joint insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Photo 5 – Asbestos-containing chilled water pipe joint insulation



Photo 6 – Asbestos-containing radiation heat tank insulation



Photo 7 – Asbestos-containing radiation heat pipe joint insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 8 – Asbestos-containing 9” x 9” black floor tile with white specks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Psychology Research (now Geography) Photo Log



Photo 9 – Non asbestos-containing plaster

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 10 – Non asbestos-containing pink sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Photo 11 – Asbestos-containing black sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 12 – Non asbestos-containing plaster

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Photo 13 – Non asbestos-containing pink sink undercoating



Photo 14 – Asbestos-containing brown vinyl stair tread

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Photo 15 – Non asbestos-containing 2' x 4' white lay-in ceiling tile with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 16 – Asbestos-containing 12” x 12” tan marble floor tile

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Psychology Research (now Geography) Photo Log



Photo 17 – Asbestos-containing 12” x 12” gray floor tile with white streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 18 – Psychology Research Building

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 19 – Assumed asbestos-containing caulk compound

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Psychology Research (now Geography) Photo Log



Photo 20 – Assumed asbestos-containing caulk compound

For more information contact MSU Environmental Health and Safety – (517) 353-8956