

MSU Parking Ramp #2 (#185)



HA #1 – Asbestos containing Black Pipe Wrap



HA #2 – Non asbestos containing 12"x12" Tan floor tile with cream streaks and associated mastic

 ${\rm HA}$ #3 - Non as bestos containing 4" Brown cove molding and associated mastic



HA #4 – Asbestos containing 2"x 2" Grey ceramic tile and associated bedding compound



HA #5 – Non asbestos containing Grey Building Caulk



HA #6 – Non asbestos containing Dark Brown Caulk



HA #7 – Asbestos containing metal jacketed steam supply and return lines



HA #8 – Non asbestos containing 2' x 4' white smooth lay in ceiling tile



HA #9 – Assumed Fire Doors