Personal Protective Equipment Hazard Assessment Certification

M	IIC	1	110	3/	N	S	T_{i}	AT	Έ
U	Ν	ī	V	F.	R	S	ī	Т	Y

Job Title: Maintenance Worker	Date : 10/16/00
Department: Power Plant, Housing	Supervisor:
Location / Worksite:	Analysis: Dan Beachnau
Employee Name(s):	Signature:

Tasks, Job Classification or Workstation	Potential Hazard	Type of PPE Required	PPE Required (Yes / No)
Power Plant Work	Hot surfaces, contact with surfaces (head), noise	Heat resistant gloves, hard hats, hearing protection	Y
Power Plant Laboratory Work	Corrosive chemicals, splashing chemicals	Safety glasses, chemical resistant gloves, apron. When pouring large quantities of chemicals, a face shield and goggles	Y
Tunnel Work	Contact (head), restricted access areas, heat stress, hot surfaces	Hard hat, light clothing, temperature resistant gloves, safety glasses	Y
Elevator Maintenance Work	Uncovered electrical switches and circuits, falling, moving machinery	Electrically insulated gloves (rated for energized voltage), fall protection, cut/puncture resistant gloves	Y
Confined Space Work	Hazardous atmosphere, restricted exit, other depending on nature of the space	Determine appropriate personal protective equipment in accordance with the Confined Space Entry Program	Y